



Webb Solutions Limited • 4427 Dawson Street, Burnaby, BC, V5C 4B8 • Tel: 604.501.6652 • Fax: 604.501.6653

Building Exception Report

Date	June 10, 2009
To	Champion Property Mgmt.
Attn	Bill Champion

Park Towers

32 Essex Lane
Vancouver

Elevator	Problem	Recommendation
Elevator #1	Equipment has not called out.	Check operation & phone line.
Elevator #2	Equipment has not called out.	Check operation & phone line.

Madison Center

1383 Hampton St.
North York

Elevator	Problem	Recommendation
Freight Elevator #3	No AC power for telephone.	Check power and wiring.

Metropolitan Mall

4500 Landmark Way
London

Elevator	Problem	Recommendation
Mall Parkade Elevator #1	Backup battery in telephone is low.	Replace soon.